

Email - phedharampuri@Gmail.com

क्रमांक 687 / लेब / लोक स्वा.यां. उपखंड धरमपुरी

दिनांक 21/09/2021

प्रति

प्राचार्य,
निमाड़ कैंब्रिज पब्लिक हाई स्कूल
धामनोद, जिला धार

विषय :- विद्यालय में पेयजल गुणवत्ता की जांच कर Safe Drinking Water and Sanitary Condition Certificate जारी करने के संबंध में।


सनदर्भ :- आपका पत्र क्रमांक 170 धरमपुरी दिनांक

.....00.....

उपरोक्त विषयांतर्गत लेख है कि संदर्भित पत्र के माध्यम से प्रेषित निमाड़ कैंब्रिज पब्लिक हाई स्कूल धामनोद, जिला धार के पिने के पानी के सेम्पल की जांच कर रिपोर्ट एवं Safe Drinking Water and Sanitary Condition Certificate संलग्न कर आपकी ओर प्रेषित हैं।

संलग्न :- 1 रिपोर्ट 01 नग

2. स्वच्छता प्रमाण पत्र


सहायक यंत्री
लोक स्वा. यां. उप-खंड, धरमपुरी
लोक स्वा. जिला-धार (म.प्र.)

PUBLIC HEALTH ENGINEERING DEPARTMENT, DIST. DHAR
SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 687


Date: 21/09/2026

It is certified that an inspection by **Mr. Radheshyam Chouhan**, Lab Incharge from Public Health Engineering Department, Dist. Dhar inspected **Nimar Cambridge Public High School Dhamnod Block Dharampuri, Dist. Dhar (M.P.)** on 17/09/2026 and found that the Nimar Cambridge Public High School Dhamnod Block Dharampuri, Dist. Dhar (M.P.) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of one Year.


Lab Incharge

P.H.E. Sub Dn. Dharampuri
Dist. Dhar (M.P.)


Assistant Engineer
P.H.E. Sub Dn. Dharampuri,
Dist. Dhar (M.P.)

Name: Mr. Mukesh Jamra

Designation: Assistant Engineer

Public Health Engineering

Sub Division Dharampuri

Dist. Dhar (M.P.)

To

Nimar Cambridge Public High School

Dhamnod Block Dharampuri

Dist. Dhar (M.P.)

Public Health Engineering Department, Dharampuri Dhar
ANALYSIS REPORT

Type of sample :- Drinking Water

Particulars of Sender :- Nimar Cambridge Public High School Dhamnod Dist. Dhar (MP)

Particulars of Sample :-Collected
by PHED

Challan No. :-

051/9999999/0215/09/26/000189

Samp
le No.

Details of sample

Date

1

R.O. Water

17-09-2026

PARTICULARS TO BE FILLED IN THE LABORATORY

Date of Receipt :- 17/09/2026

Tested Date:- 18/09/2026

Time of Receipt :- 01.00 PM

NATURE OF STUDY - CHEMICAL & BACTERIOLOGICAL ANALYSIS

Sr. No.	Characteristics	Unit	As Per BIS -10500:2012 For Drinking Water		Results			
			Requirement	Permissible Limit in the absence of Alternate Source	Sample	Sample	Sample	Sample
			(Desirable Limit)		1	2	3	4

PHYSICAL TESTS


1	Temperature	Oc	-----	-----	-	-	-	-
2	Turbidity	NTU	1	5	0.6	-	-	-
3	Colour	Hazen Units	5	15	0	-	-	-
4	Odour	-----	Unobjectiona ble	Unobjection able	Unobjection able	-	-	-

CHEMICAL TESTS


5	pH	pH scale	6.5 to 8.5	No Relaxation	8.09	-	-	-
6	Total Hardness as CaCo3	mg/l	200	600	92	-	-	-
7	Calcium as Ca	mg/l	75	200	24	-	-	-
8	Magnesium as Mg	mg/l	30	100	7.68	-	-	-
9	Total Alkalinity as CaCO ₃	mg/l	200	600	136	-	-	-
10	Chloride as Cl	mg/l	250	1000	22	-	-	-
11	Nitrate as NO ₃	mg/l	45	45	4	-	-	-

Sr. No.	Characteristics	Unit	As Per BIS -10500:2012		Results			
			For Drinking Water		Sample	Sample	Sample	Sample
			Requirement	Permissible Limit in the absence of Alternate Source				
			(Desirable Limit)					
12	Total Dissolved Solids	mg/l	500	2000	190	-	-	-
13	Iron	mg/l	0.3	1.0	0.1	-	-	-
14	Sulphate as SO ₄	mg/l	200	400	16.46	-	-	-
15	Fluoride as F	mg/l	1	1.5	0.20	-	-	-
16	Manganese,as Mn	mg/l	0.1	0.3	0	-	-	-
17	Residual Chlorine as Cl ₂	mg/l	0.2	1	0	-	-	-
BACTERIOLOGICAL TESTS								
18	Total Coliform	Per 100 ml	Nil		Nil	-	-	-
19	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-
रिमार्क :- उपरोक्त दिये गए जल नमुने मे परिक्षण किये गये सभी पेरामिटर बी आई एस 10500-2012 के अनुसार पाये गये है।								

रिमार्क :- उपरोक्त दिये गए जल नमूने में परीक्षण किये गये सभी पैरामीटर बी आई एस 10500-2012 के अनुसार पाये गये हैं।


Chemist
Sub Division laboratory
P. H. E. D. Dharampuri


Lab Incharge
Sub Division laboratory
P. H. E. D. Dharampuri


Assistant Engineer
Sub Division laboratory
P. H. E. D. Dharampuri